
Gamma and neutron dose rate measurements around the KATANA water activation loop at JSI TRIGA reactor





MOTIVATION

- ➤ Lack of water activation experiments in fusion relevant conditions
- Lack of experimental featuring **high-energy** γ **sources**
- > Lack of experimentally validated fluid activation codes/methodologies

KATANA FACILITY

- Closed-water activation loop
- ➤ Successfully commissioned in Dec. 2023
- Execution of several experiments
 - γ & n dose rate measurements: $H^*(10)$
 - Safety aspect + C/E comparison

CONCLUSIONS

- > C/E values are within 1 order of magnitude (reasonable)
- > Improvements:
 - Absolute calibration of n and detectors → flux measurements
 - fluid CFD-based activation codes → accurate modelling of source (activated water)
- Experimental campaigns: 2024, 2025, 2026+ (C) EUROfusion





KATANA: closed water activation loop

- > Well-defined and stable high energy irradiation source:
 - Gamma: 6 MeV 7 MeV
 - Neutron: ~1 MeV
- **▶** Water activation based experiments (¹6N, ¹7N, ¹9O)
- > Experimental validation of **fluid activation codes**
 - FLUNED, RSTM, ActiFlow & GammaFlow
- \triangleright Calibration of γ detectors and dosimeters
- > Shielding experiments using ITER-relevant materials
- > Integral cross-section measurements
- \triangleright Dose rates and γ spectrum measurement




relevant conditions







Gamma & neutron dose rate measurements

- Obtain dose field map + safety aspect
 - Green zone limit: 10 μSv/h (reactor hall)
- \triangleright Dose rate equivalent (H*(10)/time)
 - Max: 5 mSv/h (MP 13; flow = 0.4 l/s)



- **Calculation**: simplified convectional model without CFD
 - MCNP + analytical approach
- ➤ Underestimation for gammas → factor of 2-5 times
- ➤ Slight overestimation for neutrons → factor of 1.8





	ı			
	Snail No. $1 + Pump$			
	Calculation		\mathbf{C}/\mathbf{E}	
ИΡ	γ	neutron	γ	neutron
	$[\mu Sv/h]$	$[\mu Sv/h]$	[]	[]
0	10.6	4.31E-02	0.08	0.004
1	13.5	5.68E-02	0.45	0.006
2	26.2	1.00E-01	0.22	0.13
3	9.8	2.89E-02	0.20	0.06
4	22.9	5.71E-02	0.19	0.14
5	9.6	3.71E-02	0.18	0.37
6	0.8	5.34E-03	0.26	0.03
7	0.2	1.61E-03	0.12	N/A
8	0.1	4.29E-04	0.33	N/A
9	0.3	1.63E-03	0.22	N/A
10	1.1	1.24E-03	0.41	N/A
11	0.3	1.37E-03	0.17	N/A
12	0.0	7.20E-04	0.03	N/A
13	1397.7	3.68	0.28	1.23
14	1236.8	3.54	0.36	1.77
15	109.1	2.34E-01	0.18	0.21
16	14.8	5.04E-02	0.16	0.17
17	56.0	1.74E-01	0.17	0.16
18	0.2	6.01E-04	0.37	N/A
19	6.3	1.05E-02	0.70	N/A
20	0.7	1.03E-03	0.42	N/A